

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 01:10 pm

PWS ID: UTAH28025 **Name:** RED ROCK CAFE
Legal Contact: REDROCK CAFE **Rating:** Approved
 ED BAHR **Rating Date:** 12/10/2008
Address: PO BOX 145 **Activity Status:** Active
 HANKSVILLE, UT 84734
Phone Number: 435-542-3235
City Served (Area):
County: WAYNE COUNTY

System Type: Non-community **Last Inv Update:** 04/22/2009 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 11/04/2009 **Total Dsgn Cap:**
Population: 80 **Surveyor:** JOHN VERCOE **Total Emerg Cap:**
Oper Period: 4/1 to 9/30

Gal/Day Gal/Min

Contacts

| Contact Type | Name | Title | Phone Numbers | Email Address |
|--------------|----------|-------|-----------------------|------------------|
| | | | Office Emergency | |
| AC | BAHR, ED | | 435-542-3235 | ed_bhr@yahoo.com |

Service Connections

| Connection Type | Meter Type Code | Meter Size | Number Connections |
|-----------------|-----------------|------------|-----------------------------|
| Commercial | Unmetered | 0 | 41 |
| | | | 41 Total Svc Connections |

Storage

Total Storage: 1,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

| No. | Name | Type | Effective Volume | Constr Matrl | Overflow Elev | Activity Status | Press'd |
|-------|------------------------|-------------|------------------|--------------|---------------|-----------------|---------|
| ST001 | STORAGE FACILITY ST001 | Hydropneuma | 1,000 GAL | Steel | | A | |

Distribution System

| Pump Type | Total Dyn Head ft H2O P.S.I. | Pressure Adequate | Cross Connection | Auhority Statement |
|-----------|------------------------------------|-------------------|------------------|--------------------|
| No | | | | |

Sources

| No. | Source Name | Activity Status | Source Type | Well Dia. | Safe Yield * | Pump Capacity | Location Data On File | Water Type | Availability | Period of Operation | Grnd Wtr Indicator |
|-------|----------------------|-----------------|-------------|-----------|--------------|---------------|-----------------------|------------|--------------|---------------------|--------------------|
| WS001 | RED ROCK CAFE WELL 1 | Active | WL | 6 | 40 GPM | 10 GPM | Yes | GW | Seasonal | 4/1 to 9/30 | |

*Reports measured flow for wells, approved design capacity for all other sources.